

## **MEMORANDUM**

Our Ref: LIC/KC

Application Ref: PEL 00735

Date: 06 July 2018

From:

, Licensing Planning & Building Standards.

To:

(Licensing), Corporate Services.

Subject:

Consultation: Civic Government (Scotland) Act 1982,

Application for the Grant of a Temporary Public Entertainment Licence ref (PEL735)

Applicant: The Rangers Football Club Limited

Address: Ranger Fan Zone ,80 Hinshelwood Drive (Ibrox Football Centre)

Ward:5

Recommendation:

The Committee may grant the licence.

Items for Completion:

None

- Section 89 approval will be required in respect of any structure at a height of 600mm or above ground level.
- 2. A suitable and appropriate system of crowd management will be required to ensure the safe operation of the event and that the maximum capacity figure is not exceeded.
- 3. An appropriate event management plan and risk assessments should be provided, and should include an appropriate wind management plan.
- 4. Barrier off all Generators, power source equipment etc from the public.
- 5. Stalls or lightweight structures to be suitably fixed down to prevent uplift due to wind loadings.
- 6. All cables, wires, hoses and projections, which may pose a trip hazard or obstruction, should be kept clear of all exit points and suitably covered and/or highlighted.

It is proposed to use the all weather football pitch located off Hinshellwood Drive and accessed off Edmiston Drive as the Rangers Fan Zone area on the 22/09/18 and 23/09/18 . The event will consist of a general entertainment area including a stage with LED screens, food and Beveridge vendors, promotional kiosks and a sectioned off childrens' soccer activity area. The capacity for the event is 2000.

. Licensing Team
BUILDING CONTROL & PUBLIC SAFETY

......

cc, file



# **MEMORANDUM**

Our Ref: LIC/KC

Application Ref: PEL 00740

Date: 05 July 2018

From:

Licensing Planning & Building Standards.

To:

(Licensing), Corporate Services.

Subject:

Consultation: Civic Government (Scotland) Act 1982,

Application for the Grant of a Temporary Public Entertainment Licence ref (PEL740)

Applicant: The Rangers Football Club Limited

Address: Ranger Fan Zone ,80 Hinshelwood Drive (Ibrox Football Centre)

Ward:5

Recommendation:

The Committee may grant the licence.

Items for Completion:

None

- Section 89 approval will be required in respect of any structure at a height of 600mm or above ground level.
- A suitable and appropriate system of crowd management will be required to ensure the safe operation of the event and that the maximum capacity figure is not exceeded.
- 3. An appropriate event management plan and risk assessments should be provided, and should include an appropriate wind management plan.
- 4. Barrier off all Generators, power source equipment etc from the public.
- 5. Stalls or lightweight structures to be suitably fixed down to prevent uplift due to wind loadings.
- 6. All cables, wires, hoses and projections, which may pose a trip hazard or obstruction, should be kept clear of all exit points and suitably covered and/or highlighted.

It is proposed to use the all weather football pitch located off Hinshellwood Drive and accessed off Edmiston Drive as the Rangers Fan Zone area on the 06/10/17 and 07/10/18. The events will consist of a general entertainment area including a stage with LED screens, food and Beveridge vendors, promotional kiosks and a sectioned off childrens' soccer activity area. The capacity for the event is 2500.

. Licensing Team
BUILDING CONTROL & PUBLIC SAFETY

cc. file



# **MEMORANDUM**

Our Ref: LIC/KC

Application Ref: PEL 00739

Date: 05 July 2018

From:

Licensing Planning & Building Standards.

To:

(Licensing), Corporate Services.

Subject:

Consultation: Civic Government (Scotland) Act 1982,

Application for the Grant of a Temporary Public Entertainment Licence ref (PEL739)

Applicant: The Rangers Football Club Limited

Address: Ranger Fan Zone ,80 Hinshelwood Drive (Ibrox Football Centre)

Ward:5

### Recommendation:

The Committee may grant the licence.

Items for Completion:

None

- Section 89 approval will be required in respect of any structure at a height of 600mm or above ground level.
- A suitable and appropriate system of crowd management will be required to ensure the safe operation of the event and that the maximum capacity figure is not exceeded.
- 3. An appropriate event management plan and risk assessments should be provided, and should include an appropriate wind management plan.
- 4. Barrier off all Generators, power source equipment etc from the public.
- 5. Stalls or lightweight structures to be suitably fixed down to prevent uplift due to wind loadings.
- 6. All cables, wires, hoses and projections, which may pose a trip hazard or obstruction, should be kept clear of all exit points and suitably covered and/or highlighted.

It is proposed to use the all weather football pitch located off Hinshellwood Drive and accessed off Edmiston Drive as the Rangers Fan Zone area on the 15/09/18 and 16/0918. The events will consist of a general entertainment area including a stage with LED screens, food and Beveridge vendors, promotional kiosks and a sectioned off childrens' soccer activity area. The capacity for the event is 2500.

. Licensing Team
BUILDING CONTROL & PUBLIC SAFETY

cc. file



## MEMORANDUM

Our Ref: LIC/KC

Application Ref: PEL 00730

Date: 22 June 2018

From:

7

Licensing Planning & Building Standards.

To:

(Licensing), Corporate Services.

Subject:

Consultation: Civic Government (Scotland) Act 1982,

Application for the Grant of a Temporary Public Entertainment Licence ref (PEL730)

Applicant: The Rangers Football Club Limited

Address:

Ranger Fan Zone ,80 Hinshelwood Drive (Ibrox Football Centre)

Ward:5

Recommendation:

The Committee may grant the licence.

Items for Completion:

None

- Section 89 approval will be required in respect of any structure at a height of 600mm or above ground level.
- 2. A suitable and appropriate system of crowd management will be required to ensure the safe operation of the event and that the maximum capacity figure is not exceeded.
- 3. An appropriate event management plan and risk assessments should be provided, and should include an appropriate wind management plan.
- 4. Barrier off all Generators, power source equipment etc from the public.
- 5. Stalls or lightweight structures to be suitably fixed down to prevent uplift due to wind loadings.
- 6. All cables, wires, hoses and projections, which may pose a trip hazard or obstruction, should be kept clear of all exit points and suitably covered and/or highlighted.

It is proposed to use the all weather football pitch located off Hinshellwood Drive and accessed off Edmiston Drive as the Rangers Fan Zone area on the 11/08/18. The event will consist of a general entertainment area including a stage with LED screens, food and Beveridge vendors, promotional kiosks and a sectioned off childrens' soccer activity area. The capacity for the event is 2000.

. Licensing Team
BUILDING CONTROL & PUBLIC SAFETY

cc. file